



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/06/2025

Area: WT

Equipment	Job
OP 10	D4,motor changing done ,old motor removed and shifted ,spare motor placed (testing is pending)
CP 2	Aux.relay provided for Vacuum/Main contactor due to block problem ,tested,OK
OP 1 and 6	after rake maintenance done
OP 4	after rake maintenance done,Top pad and one jumper replaced