



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/06/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED	RESET DONE	04:20:00	04:35:00	
2	OHP	CO-6A WOBR	BC STOPPING ON ZSS	CAGE STUCK UP ... MADE FREE	03:35:00 22:15:00	03:50:00 22:30:00	
3	CHP	CC-132	TRIPPED ON OVER LOAD	RESET DONE	00:45:00	00:55:00	
4	CHP	CC-131	TRIPPED ON OLR	RESET DONE	01:30:00	01:35:00	
5	CHP	RG-3 F/G	MPCB TRIPPED	MADE ON	01:30:00	01:35:00	
6	CHP	CC-115	BRS BYPASS REQUEST DUE TO HOLE	BYPASSED	01:30:00	01:35:00	
7	CHP	CC-44	TRIPPED ON OLR	RESET DONE	01:58:00	02:05:00	
8	CHP	CC-32 SCR-5	LT NOT WORKING	TRIPPED ... RESET	03:00:00	03:20:00	
9	CHP	CC-33	TRIPPED ON OLR	RESET DONE	03:28:00 04:15:00	03:35:00 04:25:00	
10	CHP	CC-40 SCR-6	SLEW NOT WORKING	DUE TO MATERIAL JAMMING ... INFORMED OPERATION FOR CLEANING	04:10:00	04:20:00	
11	CHP	CC-103	STOPPED ON ZSS	COAL STUCK IN CAGE ... REMOVED	03:20:00	03:30:00	
12	CHP	CC-33 SCR-4	BC STOPPED CAGE REVERSED	FIXED PROPERLY	05:34:00	05:45:00	