



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/05/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 8A	BW 2 stopping on ZSS	ZSS bypassed in module and tested	00:25:00	00:45:00	gap adjusted and kept in circuit
2	OHP	CO 32 and COP 36A	BRS kept in circuit	okay	22:30:00	22:40:00	
3	OHP	BRC on CO 34	BW 2 not rotating	Due to heavy load. No electrical problem.	23:55:00	00:15:00	
4	OHP	BRC on CO 34	BW 1 not rotating	Chain problem. Informed to mechanical and operation	05:00:00	05:15:00	
5	CHP	CC 44	Tripped in overload	reset done	01:30:00 04:30:00	01:40:00 04:40:00	
6	CHP	CC 43	Tripped in overload	reset done	04:30:00	04:40:00	
7	CHP	CC 104 , SCR 9	BW not running	fault reset	02:30:00	02:45:00	
8	CHP	CC 117	Tripped in overload	reset done	23:55:00	00:10:00	
9	CHP	CC 54	Tripped in overload	reset done	00:05:00 03:40:00 05:00:00	00:30:00 03:45:00 05:05:00	
10	CHP	CC 131	Tripped in overload	reset done	04:15:00	04:20:00	
11	CHP	CC 113	BSS acted due to belt off centering	BSS bypassed for mechanical work , again kept in circuit	00:00:00	00:10:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/05/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC 115 , CC 116	BRS acting due to dust	Bypassed as per operation request	00:00:00	00:10:00	Bypassed in system
13	WT	CO 3	Carriage drive not moving in outhaul side , OLR tripping	OLR reset done . Contactor tips cleaned and tested	05:00:00	05:30:00	