



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/05/2025

Area: WT

| Equipment | Job |
|-----------|---|
| AF 3(O) | local Inch start push button replaced |
| OT 5 | out haul side lighting ,circuit problem rectified and kept in timer circuit |
| | lighting problem rectified 3 nos 150W SV and 1no 35W LED replaced |
| CP 4 | |
| OP 3 | D4 one lug found cut in motor TB ,replaced and 1no top jumper replaced |
| | after rake maintenance done |

CO 5,6 &7 tunnel

OP 2,3,4,5,6,7 &10