



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/12/2025

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment     | Problem   | Action                              | From                 | To                   | Remarks          |
|-------|------|---------------|---|-------------------------------------|----------------------|----------------------|------------------|
| 1     | OHP  | CO-29         | OLR ACTED   | RESET DONE                          | 10:40:00             | 10:45:00             |                  |
| 2     | OHP  | CO-26         | OLR ACTED   | RESET DONE                          | 10:10:00             | 10:20:00             |                  |
| 3     | OHP  | CO-9A         | REPORTED STOPPING ON ZSS FOUND ZSS PROBE DAMAGED            | PROBE REPLACED WITH NEW ONE THAN OK | 10:50:00             | 11:15:00             |                  |
| 4     | OHP  | BRC ON CO-32  | REPORTED B/W-1 NOT RUNNING FOUND GUIDE ROLLER PROBLEM       | INFORMED TO OPERATION               | 07:05:00             | 07:20:00             |                  |
| 5     | OHP  | BRC ON CO-28  | REPORTED ALL DRIVES ARE NOT RUNNING FOUND E/STOP ACTED      | RELEASED                            | 07:30:00             | 07:45:00             |                  |
| 6     | OHP  | WOBR ON CO-25 | REPORTED B/W NOT RUNNING FOUND POWER MCCB TRIPPED           | B/W MOTOR BURNT                     | 11:30:00             | 12:00:00             | G SHIFT ATTENDED |
| 7     | CHP  | CC-117        | OLR ACTED (2TIMES)  | RESET DONE                          | 06:05:00<br>10:15:00 | 06:15:00<br>10:25:00 |                  |
| 8     | CHP  | CC-51         | MPD ACTED FEEDING CONVEYOR (6TIMES)                         | RESET DONE                          | 08:00:00             | 11:15:00             |                  |
| 9     | CHP  | CC-52         | MPD TRIPPED (FEEDING CONVEYOR)                              | RESET DONE                          | 12:50:00             | 12:55:00             |                  |
| 10    | CHP  | CC-54         | OLR ACTED   | RESET DONE                          | 08:40:00             | 08:45:00             |                  |
| 11    | CHP  | CC-39 SCR-6   | REPORTED LT NOT WORKING FOUND DRIVE TRIP FAULT CODE OF-7404 | RESET DONE                          | 07:00:00             | 07:10:00             |                  |
| 12    | CHP  | CC-39 SCR-6   | LT DRIVE TRIP FAULT CODE OF-30002                           | RESET DONE                          | 07:50:00             | 08:00:00             |                  |
| 13    | CHP  | CC-32 SCR-5   | B/C NOT RUNNING BELT SLIPPING                               | INFORMED TO MECHANICAL              | 07:45:00             | 07:55:00             |                  |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/12/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment      | Problem  | Action                        | From     | To       | Remarks |
|-------|------|----------------|--|-------------------------------|----------|----------|---------|
| 14    | CHP  | CC-32<br>SCR-5 | B/C TRIPPED ON OLR   | RESET DONE                    | 08:40:00 | 08:50:00 |         |
| 15    | CHP  | CC-33<br>SCR-3 | B/W NOT RUNNING  | FAULT RESET DONE THAN OK      | 09:00:00 | 09:10:00 |         |
| 16    | CHP  | CC-40<br>SCR-2 | SLEW NOT WORKING FOUND DRIVE TRIP<br>AND 30 DEGREE LIMIT ACTED | RELEASED AND DRIVE RESET DONE | 11:25:00 | 11:40:00 |         |
| 17    | WT   | OT-4           | DRIVE -2 TRIP PGF-4 FAULT                                      | RESET DONE                    | 13:55:00 | 14:00:00 |         |