



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/07/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR acted	reset done	01:43:00	01:53:00	
2	OHP	BRC on CO 33M	BW not rotating	Oil level low, informed to operation	02:35:00	02:50:00	
3	OHP	BRC on CO 34	BW 2 stopping on zss	Module problem , bypassed in module	03:40:00	04:00:00	to be kept in ckt
4	OHP	CO 35	OLR acted	reset done	01:20:00	01:25:00	
5	OHP	CO 26	BRS bypass request from operation due to belt hole	bypassed in module	00:30:00	00:45:00	
6	OHP	TT 1	Chute vibrator not working	MPCB tripped . Meggar done , IR value zero	01:30:00	02:00:00	to be changed
7	OHP	VS 4A	OLR acted	reset done	23:10:00	23:20:00	
8	CHP	CC 104 , SCR 9	LT not working due to Overtension acted ( 4 times)	tension released	23:00:00	05:00:00	
9	CHP	CC 111, R-1	BC not running due to zss interlock feedback missing	Checked, cage sticking . Cage changed	23:35:00	00:40:00	
10	CHP	CC 32	Tripped on overload	reset done	23:15:00	23:35:00	
11	CHP	CC 114	Tripped on overload	reset done	02:10:00	02:20:00	
12	CHP	CC 51	MPD tripped on overload	reset done	00:50:00 01:15:00	00:55:00 01:20:00	
13	CHP	CC 105, SCR 7	PCRD chain broken	PCRD drum arrested after mechanical work unsuccessful . Four loop on drum and pcrd power made off	22:30:00	23:45:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OT 5	LS 1 stucked	bypassed	22:30:00	22:35:00	again kept in ckt
15	WT	CO 3	Belt drive OLR acted	reset done	02:25:00 03:20:00 05:15:00	02:35:00 03:30:00 05:25:00	
16	IOSA	FLS wobr	BC not running	Interlock zss cage stucked, made free	02:25:00	02:40:00	