



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/02/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment          | Problem   | Action                 | From                 | To                   | Remarks |
|-------|------|--------------------|---|------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CR 3A              | crusher permissive not coming,solenoid switch problem | switch replaced        | 15:45:00             | 16:35:00             |         |
| 2     | OHP  | CO 26              | olr acted   | reset                  | 20:00:00             | 20:10:00             |         |
| 3     | OHP  | CO 34              | olr acted   | reset                  | 21:30:00             | 21:40:00             |         |
| 4     | CHP  | CC 102 TT on CC106 | signal not coming                                     | given high in I/O rack | 15:00:00             | 15:15:00             |         |
| 5     | CHP  | CC 58              | OLR acted   | reset                  | 15:10:00             | 15:20:00             |         |
| 6     | CHP  | CC 51              | MPD acted   | reset                  | 21:20:00             | 21:25:00             |         |
| 7     | CHP  | cc 54              | OLR acted   | reset                  | 18:25:00             | 18:30:00             |         |
| 8     | CHP  | CC 31              | olr atced   | reser                  | 18:05:00             | 18:10:00             |         |
| 9     | CHP  | CC 106             | ZSS acted,ZSS module problem                          | module replaced        | 16:05:00             | 16:15:00             |         |
| 10    | CHP  | CC 216             | Olir acted  | reset                  | 16:45:00             | 16:50:00             |         |
| 11    | CHP  | CC 104 SCR7        | LT not working,PCRD OT acted                          | OT released            | 17:30:00             | 17:35:00             |         |
| 12    | CHP  | CC 40 SCR2         | ZSS probe damaged                                     | PROBE replaced         | 17:45:00             | 17:55:00             |         |
| 13    | CHP  | CM18               | all conveyor red,no power,,ACB tripped in LC 18       | made it on             | 18:00:00<br>18:30:00 | 18:10:00<br>18:40:00 |         |