



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/01/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 3	ZSS CAGE GOT TILTED AND PROBE DAMAGED	PROBE REPLACED	19:00:00	19:30:00	
2	OHP	TT2	POWER CABLE OLD JOINT GOT OPENED INTERNALLY	PROPERLY CONNECTED THEN OK	17:00:00	18:45:00	
3	OHP	CO 26	OLR ACTED	RESET	17:50:00	17:55:00	
4	OHP	CO 20 BRS	CONTROL FUSE DAMAGED IN I/O RACK	REPLACED	20:10:00	20:20:00	
5	OHP	CO 11A, CO 31A NOT RUNNING	TRIPPED IN 1-2 LBDS8	MADE IT ON	16:50:00	17:20:00	
6	CHP	CP 4	EMERGENCY STOP ACTED NEAR DEAD END	RELEASED	20:00:00	20:15:00	
7	CHP	CC 51	FEEDING CONV MPD ACTED	RESET	16:00:00	21:30:00	16 TIMES
8	CHP	CC 54	OLR ACTED	RESET	18:00:00	20:00:00	3 TIMES
9	CHP	CC 131	OLR ACTED	RESET	16:30:00	20:00:00	3 TIMES
10	CHP	CC 117	OLR ACTED	RESET	18:30:00 21:40:00	18:40:00 21:45:00	
11	CHP	SCR 6 ON CC 39 SLEW	LIMIT ACTED DUE TO COAL JAMMING	INFORMED TO OPRN	15:35:00	15:45:00	
12	CHP	SCR 8 ON CC 112	B/C OLR ACTED	RESET	17:25:00	17:40:00	
13	CHP	SCR 9 ON CC 104 LUFF	MPCB TRIP	RESET	17:25:00	17:35:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/01/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 32	OLR ACTED	RESET	21:00:00	21:10:00	