



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/05/2025

Area: OHP

Equipment	Job
CO-8A,DB-1,37A	MOTOR, PANEL , CJD PPM IS DONE.
HT COUPLERS	SPACE HEATERS INSPECTION IS DONE.
WOBR-1,2,3	B/W MOTOR INSPECTION IS DONE.
TBS-1 ON CO-21	PCRD MOTOR IS REPLACED WITH SPARE ONE, REMOVED MOTOR SHIFTED TO HVMCC-1 AND COUPLING REMOVED.
TBS-5 ON CO-23	PPM IS DONE
CO-16A,16B,17A,17B	MOTOR, PANEL , FIELD DEVICES PPM IS DONE. INDICATION LAMPS CHANGED FOR CO-16A BRS MODULE.
CO-5,6 TUNNEL	ILLUMINATION IS IMPROVED.
JH O-3	LDB PPM IS DONE