



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 13/11/2025

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|--|--|----------------------------------|----------------------------------|-------------------------------------|
| 1 | OHP | CO 11 CD | OLR ACTED | RESET | 00:05:00 | 00:15:00 | |
| 2 | OHP | BRC ON CO 28 LT | CONTROL MCB TRIPPED | MADE IT ON THEN OK | 22:50:00 | 23:00:00 | |
| 3 | OHP | BRC ON CO 28 LT | CRMP SIDE MATERIAL JAMMING DRIVE TRIPPED | RESET | 23:30:00 | 23:45:00 | |
| 4 | OHP | CO 26 | OLR ACTED | RESET | 01:15:00 03:00:00 22:20:00 | 01:25:00 03:10:00 22:30:00 | |
| 5 | OHP | TBS ON CO 5A | ACB TRIPPED | MADE IT ON | 00:40:00 | 01:10:00 | |
| 6 | OHP | WBR ON CO 26 | SLEW DRIVE TRIPPED | RESET | 02:15:00 | 02:30:00 | |
| 7 | OHP | CO 29 | OLR ACTED | RESET | 03:50:00 | 04:00:00 | |
| 8 | OHP | VF 1A | M1 MPCB TRIPPED DUE TO JAMMING | MADE IT ON | 03:40:00 | 03:55:00 | |
| 9 | CHP | CC 18 | MCCB OUTGOING B PHASE FEMALE FINGER CONTACTOR MELTED | MALE CONTACTOR PROPERLY CLEANED AND SPARE MCCB MODULE RACKED IN AND TESTED | 23:00:00 | 23:45:00 | MALE FINGER CONTACTOR TO BE CHECKED |
| 10 | CHP | CO 19 | MPD ACTING ON UNDER CURRENT | DISABLED | 23:20:00 | 23:30:00 | |
| 11 | CHP | CC 54 | OLR ACTED | RESET | 00:10:00 | 00:20:00 | |
| 12 | CHP | CC 51 | FEEDING CONVEYOR OLR ACTED | RESET | 23:00:00 | 05:30:00 | 15 TIMES |
| 13 | CHP | CC 131 | OLR ACTED | RESET | 00:15:00 | 05:35:00 | 4 TIMES |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/11/2025

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------|--|-----------------------------|----------------------|----------------------|----------|
| 14 | CHP | CC 31, 32, 33 RED | CM 22 TRIPPED | MADE IT ON | 22:25:00 | 22:35:00 | |
| 15 | CHP | CC 49 ZSS MODULE | SHIFTED NEAR MOTOR | KEPT IN CIRCUIT | 22:30:00 | 23:00:00 | NO DELAY |
| 16 | CHP | SCR 5 ON CC 33 | LT DRIVE TRIPPED | RESET | 00:05:00 00:40:00 | 00:15:00 01:00:00 | |
| 17 | CHP | CC 45 | OLR ACTING DUE TO TAIL END JAMMING | RESET AND INFOREMED TO OPRN | 03:30:00 | 03:40:00 | |
| 18 | WT | CT1 | WAGON SENSOR ACTED | WAGON PLACED PROPERLY | 00:00:00 | 00:10:00 | |
| 19 | WT | OT5 | DRIVE 2 TRIPPED ON SHORT CIRCUIT FAULT | RESET THEN RUN OK | 01:00:00 | 01:10:00 | |
| 20 | WT | AF4 | DRIVE TRIPPED ON SPEED DEVIATION FAULT | RESET | 05:15:00 05:35:00 | 05:20:00 05:40:00 | |