



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 31/05/2025

Area: CHP

Equipment	Job
SCR 1 to 10	Cable chamber inspection was done
Stacker 3	Running inspection was done
SCR 7	HT cable dressing done
CC 223	Drive end and gallery lighting ckt problems rectified and improved lighting
CC 27,27A,46	PPM was done
Reclaimer 1	Slew one end limit Proximity switch and AUX. relay replaced and tested the limits