



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 01/02/2026

Incharge(s): Lal Singh,Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-1A CD	TRIPPED ON OLR	RESET DONE	00:30:00	00:40:00	
2	OHP	RSCO-6A CD	TRIPPED ON OLR	RESET DONE	00:15:00	00:30:00	
3	OHP	VS-1A	OLR ACTED	RESET DONE	02:05:00	02:15:00	
4	OHP	WBR ON CO-25	LT DRIVE TRIPPED ON OL	RESET DONE	03:32:00	03:48:00	
5	OHP	WBR ON CO-25	SLEW DRIVE TRIPPED	RESET DONE	03:50:00	03:54:00	
6	OHP	CO-84	OLR ACTED	RESET DONE	04:05:00 04:20:00	04:15:00 04:25:00	
7	OHP	CO-29 WBR	BC NOT RUNNING	FAULT RESET DONE THEN OK	23:00:00	23:10:00	
8	CHP	CC-37 SCR-3	BC TRIPPED ON OLR	RESET DONE	23:15:00	23:30:00	
9	CHP	CC-112 SCR -8	NO POWER ... HT CABLE CAME OUT OF COUPLER IC SIDE	CABLE LOOP PROVIDED .. COUPLER OPENED AND INFORMED TO DNW	04:15:00	06:00:00	
10	CHP	CC-51	MPD TRIPPED 4 TIMES	RESET DONE	02:55:00	05:15:00	
11	CHP	CC-29	OLR ACTED 4 TIMES DUE TO MATERIAL OVERLOAD	RESET DONE	00:00:00	02:55:00	
12	CHP	CC-110	COAL STUCK IN ZSS CAGE	REMOVED	02:20:00	02:35:00	