



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 08/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 33M	LT not working,PCRD OT acted	released	08:30:00	08:40:00	guide problem
2	OHP	BRC on CO 28	all drive not working,acb tripped	ACB made on	11:55:00	12:05:00	
3	OHP	wobr on co 29	b/c not running	operator cabin reset	10:55:00	11:00:00	
4	OHP	1-28 HVMCC 4	oc 9a,11a,3a no power,l/c 2 tripped in LBDS 8	made it on by CRP	13:40:00	14:05:00	
5	CHP	CC 28(B)	olr acted	reset	10:40:00	10:47:00	
6	CHP	CC 117	olr acted	reset	08:35:00	08:50:00	
7	CHP	CC 113A	olr acted	reset	12:22:00	12:25:00	
8	WT	CO 4(C)	olr acted	reset	11:20:00	11:25:00	
9	IOSA	LBDS 2 6.6 KV hvmcc 5	i/c 1 tripped	made it on by CRP panel	06:40:00	06:50:00	