



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/10/2025

Shift: C

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	DB-1	TRIPPED ON OLR	RESET DONE	00:30:00	00:45:00	
2	OHP	CO-26	TRIPPED ON OLR	RESET DONE	00:40:00	00:50:00	
3	OHP	TBS ON CO-7A	REPORTED L/LUFF NOT TAKING PLACE FOUND LIMIT ACTED	LIMIT RELEASED THAN OK	01:30:00	01:50:00	
4	OHP	CO-85	TRIPPED ON OLR (2TIMES)	RESET DONE	02:20:00 03:30:00	02:30:00 03:40:00	
5	OHP	BRC ON CO-31	B/C TRIPPED ON OLR DUE TO BELT OFFCENTER	RESET DONE	04:40:00	04:50:00	
6	OHP	TT-4 ON CO-3A	REPORTED POSITION INDICATION MISSING ON CO-7A CHECKED AND FOUND PROBE WIRE GOT CUT	JOINT DONE THAN OK	01:25:00	01:45:00	
7	CHP	CC-18	STOPPING ON ZSS FOUND ZSS CAGE STUCK WITH MATERIAL	MATERIAL CLEANED THAN OK	03:00:00	03:10:00	
8	CHP	CC-51	TRIPPED ON MPD (5TIMES) DUE TO FEEDING CONVEYOR STOP	RESET DONE	23:00:00	05:00:00	
9	CHP	CC-51	OLR ACTED	RESET DONE	01:10:00	01:20:00	
10	CHP	CC-54	TRIPPED ON OLR (5TIMES)	RESET DONE	04:30:00	05:30:00	DUE TO MATERIAL OVER FEEDING
11	CHP	CC-36 S-1	REPORTED LT NOT TAKING PLACE CHECKED AND FOUND PCRD O/T ACTED	O/T RELEASED AND PCRD CABLE PROPER LAYERING WAS DONE	00:50:00	01:30:00	
12	CHP	CC-33	MOTOR TRIPPED ON OLR	RESET DONE	02:20:00	02:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/10/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-38 ,44,125,126	REPORTED NOT HEALTHY CHECKRD AND FOUND PLC COMMUNICATION MISSING BETWEEN LC-18,CM-17 ,CM-18 DUE TO CABLE CUT BY RAT	PROPY BUS CABLE LAYING BETWEEN LC-18 , CM-17,CM-18 AND CONNECTED THAN OK	01:30:00	06:00:00	