



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 21/11/2025

Area: WT

Equipment	Job
CP 1	After rake maintenance done
OP2,4,6 and 7	After rake maintenance done
OP 6	5A2, rotor cantactor coil found burnt, replaced it
OP 6	D5 and D6 checked in de clutch found cascade time not rotating ( to be rectified)
MIs	13 nos C clamps assembled for pusher
MIS	vacum cantactor (3TF68) repaired and tested ,kept as spare
MIS	spare Brake Panel shifted and kept as spare in LC 9