



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 58	mpcb tripped due to overload	made it on	07:25:00	07:30:00	
2	OHP	TBS on Co 7A	luff not taking place,olr acted	reset	07:10:00	07:25:00	
3	OHP	TBS on Co 21	Lt not taking place,M4 mpcb tripped	made it on	09:37:00	09:50:00	
4	OHP	BRC on Co 8A	b/c not running,MCCB tripped ,motor winding one phase got opened	motor changing going on by G shift	09:40:00	10:00:00	
5	OHP	WOBR on Co 29	LT not taking place,M3 overload due to track jamming	reset	11:30:00	11:40:00	
6	OHP	CO 67	olr acted	reset	12:00:00	12:10:00	
7	OHP	CO 26	olr acted	reset	12:42:00	12:50:00	
8	OHP	BRC on CO 32	B/c not running,E pb acted near operator cabin	E PB released	12:45:00	13:00:00	
9	OHP	RCO 1A	ZSS acted,zss probe damaged	probe replaced	07:45:00	08:00:00	
10	OHP	TIS 1 on CO5	not healthy,mpcb tripped ,v belt got cut	made it on	11:00:00	11:10:00	informed mechanical
11	CHP	CC 104 SCR9	slew not working,mpd tripped due to overload	reset	07:25:00	07:35:00	
12	CHP	CC 33 SCR 5	b/c not running,belt slipping	informed mechanical	07:30:00	07:40:00	
13	CHP	cc 35 scr3	b/c not running,belt slipping	informed mech	09:14:00	09:25:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 38 SCR6	LT not working,M2 and M3 tripped due to jamming	informed operation	10:10:00	10:20:00	
15	CHP	CC 37 SCR7	Lt not working, track jamming motor2,3 and 4 , tripped	reset	11:10:00	11:20:00	
16	CHP	C C 35 SCR 3	b/ c not running,belt slipping	informed mechanical	11:15:00	11:30:00	
17	CHP	CC 38 scr 6	b/c not running,belt snapped	informed mechanical	13:00:00	13:10:00	
18	CHP	CC 113 A	olr acted	reset	13:15:00	13:20:00	
19	CHP	LC 19	I/C 1 tripped in E/F 51G due to LDB	reset ,isolated e/f ,made I/C on	11:30:00	11:40:00	
20	WT	OT1	d1 tripped in pgf1 fault	reset	06:30:00	06:35:00	