



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/06/2025

Area: CHP

| Equipment | Job |
|--------------------------|---|
| CC 31,38,49,50,R 1,SCR 3 | Running inspection was done |
| CC 222,223 gallery | Lighting ckt problem rectified and improved lighting |
| CCR | Micro logic PLC replaced to resolve communication issue |
| CC 15,26A, 36,37,SCR 1 | PPM was done |