



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/02/2026

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-11 (C DRIVE)	MPCB TRIP	RESET DONE	06:55:00	07:00:00	
2	OHP	CO-12A	BRS NOT HEALTHY	SENSORS CLEANED RESET DONE THAN OK	06:40:00	06:50:00	
3	OHP	CO-5A	BRS FREQUENTLY ACTED FOUND BELT PIECE HANGING	BELT PIECE REMOVED BY OPERATION THAN BRS RESET OK	07:45:00	08:00:00	
4	OHP	BRC ON CO-31	REPORTED CT NOT TAKING PLACE FOUND GUIDE ROLLER PROBLEM	INFORMED TO OPERATION AND MECHANICAL	09:50:00	10:00:00	
5	CHP	CC-51	MPD TRIP ( 6TIMES) FEEDING CONVEYOR STOP	RESET DONE	07:55:00	13:05:00	
6	CHP	CC-223	REPORTED NOT HEALTHY C-2 NOT PICK UP	POWER RE-CYCLE AND AUTO MODE TO OPERATION MODE CHANGE IN CCR	07:30:00	07:45:00	
7	CHP	CC-37 SCR-3	B/C ZSS BY-PASSED IN C SHIFT DUE PROBE PROBLEM	ZSS PROBE REPLACED AND BY-PASS REMOVED	08:00:00	08:15:00	
8	CHP	CC-213	C/S NOT HEALTHY	SENSOR CLEANED RESET DONE THAN OK	08:40:00	08:50:00	
9	CHP	CC-218	C/S ACTED	SENSOR CLEANED THAN OK	09:40:00	09:50:00	
10	CHP	CC-105 SCR-10	LT NOT TAKING PLACE M-2 MPCB TRIP	MADE ON THAN OK	11:30:00	11:40:00	
11	WT	OT-4	DRIVE-1 TRIP	RESET DONE	10:15:00	10:20:00	