



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 23/12/2025

Area: CHP

Equipment	Job
CC-113,CC-130 CHUTE VIBRATORS	cable defects rectified and tested ok
CC-109,CC-110 spare motor	cleaning and meggar values noted. found ok
JH-1 and CC-110 H/E Hoists	ppm work done
CC-7,CC-110	motor and panel side ppm done
LC-15 to LC-16 profibus cable	Profibus cable junction boxes closed along the TT gallery
SCR-1	PCRD cable winding done after mechanical repair of chain
COB-5 C-1 UPS SUPPLY	UPS -1 incoming supply changed from IMCC-7F1 to PDB 3F2 feeder and charged
SCR-2 LIGHTING	Lighting faults rectification done and sufficient lighting provided
CC-49 spare motor	Coupling removed and fixed to new motor. New motors shifted to CC-49 H/E. Old spare motor shifted to LBDS-4