



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/08/2025

Area: CHP

Equipment	Job
CC-32 FG,CC-33 FG	flap gate area cleaning, cable dressing and blowing done
CC-56	motor and panel ppm done
CC-45,47,50,35,SCR-1	ppm done
Misc	Spare motor shifted from LBDS-4 to JH-18 for CC-45 motor spare
SCR-10	LT, PCRD, BOOM CONVEYOR, SLEW, BUCKET WHEEL TRAIL RUN TAKEN AND FOUND OK