



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/10/2025

Area: CHP

| Equipment | Job |
|-------------|-------------------------------------------------------------------------------------------------------------|
| CC-40,CC-37 | Running inspection done |
| STK-3 | Slew drive modification completed. Slew movement checked with proper direction. Motors canopy also arranged |
| STK-3 | Lower E-House roof work completed |
| STK-3 | Slew drive second motor coupling fixed, mounted on base, tested with drive. made ok |