



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/05/2025

Shift: C

Incharge(s): Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-29	tripped on olr	reset done	22:35:00	22:40:00	
2	OHP	co-12	nor running	zss cage ston stuck ... made free	23:50:00	00:10:00	
3	OHP	co35	tripped on olr	reset done (3 times) due to deck sheet jamming	00:10:00	00:15:00	
4	OHP	vf-9	not running	power was in off ... made on	00:55:00	01:15:00	
5	OHP	co-7 and co-5	brs bypass request from operation	bypassed	03:00:00	03:10:00	
6	OHP	co-22 tbs	r-luff not working	olr acted ... reset done	02:40:00	03:00:00	
7	OHP	co-26 wobr	no drives working	control off due to down E LS.. luff up done by bypassing ... then tested	04:10:00	04:25:00	
8	CHP	cc-27a	flap gate tripped	reset done	01:50:00	02:00:00	
9	CHP	cc-54	tripped on olr	rest done	01:20:00	01:25:00	
10	CHP	cc-131	tripped on olr	reset done	05:30:00	05:35:00	
11	CHP	cc-32 scr-5	bc stoped on dis chut sensor	bypassed	23:50:00	00:15:00	again kept in ckt
12	CHP	cc-36 scr-1	luff not working	olr acted ... reset	00:30:00	00:50:00	
13	CHP	cc-35 scr-2	pcrd cable stuck between drum and frame	cable adjusted	02:15:00	03:15:00	
14	CHP	op-9	reverse not moving ... limit acted	released	03:40:00	04:00:00	
15	WT	ct-1 inhaul	mpcb tripped	made on	22:30:00	22:40:00	
16	WT	cp-1	d-6 tripping ... lug cut	made off and bypassed in program	23:40:00	00:15:00	
17	WT	ot-1	drive -1 tripping on pgf fault	reset done ...buffer problem ... informed mech	02:00:00	04:30:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/05/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
18	IOSA	oc-25a	tripped on olr	reset done	01:00:00	01:25:00	