



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 19/08/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-11(B/D)	Reported tripped	MPCB tripped due to jamming.Given in local for clearing jamming.Jamming cleared and tested okay	07:20:00 13:20:00	08:00:00 13:30:00	
2	OHP	CO-67	Reported tripped	OLR acted.Reset done	08:00:00	08:10:00	
3	OHP	VS-1A	Reported tripped	OLR acted.Reset done	06:47:00	06:55:00	
4	OHP	BRC on CO-30	Reported LT not taking place	Drive tripped.Reset done(2times)	08:25:00 09:20:00	08:40:00 09:30:00	
5	OHP	WOBR on CO-26	Reported Slew not taking place	Drive tripped on overload.Reset done	09:30:00	09:45:00	
6	OHP	BRC on CO-31	Reported LT not taking place	M6 tripped.Reset done	12:30:00	12:40:00	
7	OHP	BRC on CO-34	Reported B/W-1 ZSS acting.	Checked and found chain fallen	09:15:00	09:25:00	informed to operation
8	OHP	CO-29	Reported tripped	OLR acted.Reset done	13:00:00	13:15:00	
9	CHP	CC-29	CJD acted	Probe cleaned and tested okay	07:20:00	07:30:00	
10	CHP	CC-19(B/D)	Reported tripped	OLR acted.reset done	12:30:00	12:45:00	
11	CHP	CC-112 S-3	LT reverse not taking place	M2,3,5 tripped due to material sliding onto track.reset done	07:35:00	07:50:00	Informed to operation to clean track
12	CHP	CC-39 s-1	Luffing not working	Wrong complaint	08:17:00	08:25:00	
13	CHP	CC-32 SCR-5	LT not taking place	Drive tripped. reset done and tested okay	09:28:00	09:38:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/08/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-38 SCR-6	B/C not working	OLR acted.Reset done	09:38:00	09:50:00	
15	CHP	Cc-35 SCR-1	LT not working	OT acted.Released	10:30:00	11:00:00	Track jamming informed to operation
16	CHP	CC-203	Reported tripped	OLR acted.Reset done	13:00:00	13:10:00	
17	CHP	CC-54	Reported tripped	OLR acted due to decksheet jamming	10:20:00	10:34:00	Tripped 7 times 11.09, 11.18, 11.22, 11.30, 11.42
18	CHP	RG-2 F/G	Reported tripped.	OLR acted.reset done	07:30:00	07:40:00	
19	WT	OT-1	Initial not coming	Rotary limit switch adjusted and tested okay	08:30:00	08:35:00	