



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 11/10/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	05:20:00 23:15:00	05:30:00 23:30:00	
2	OHP	CO-10A	TRIPPED ON OLR	RESET DONE	23:50:00	00:00:00	
3	OHP	CO-26	TRIPPED (2 TIMES )	RESET DONE	00:40:00 04:05:00	00:45:00 04:10:00	
4	OHP	CO-31 BRC	BC TRIPPED ON OLR	RESET DONE	01:20:00	01:35:00	
5	OHP	TBS ON CO 24	R LUFF OLR TRIPPED	RESET DONE	03:10:00	03:30:00	
6	OHP	CO-31 BRC	YARD RUNNING INDICATION MISSING IN CABIN	WIRE LOOSE IN ZSS MODULE ... FIXED	03:45:00	04:00:00	
7	OHP	WBR ON CO -6A	LT M-4 TRIPPED	RESET DONE	04:45:00	05:00:00	
8	CHP	CC-29 FG	TRIPPED	RESET DONE	04:00:00	04:10:00	
9	CHP	CC-21 CD	TRIPPED	RESET DONE	00:30:00	00:40:00	
10	CHP	CC-112 SCR-8	SLEW NOT WORKING	30DEGREE LIMIT ACTED	22:54:00	23:08:00	
11	CHP	CC-34 SCR-7	BC NOT WORKING	OLR ACTED ... RESET	00:50:00	01:00:00	
12	CHP	CC-36 SCR-1	LT NOT WORKING ... M4 TRIPPED . AND PCRD OT ACTED	RESET AND RELEASED	01:05:00 02:12:00 03:45:00	01:15:00 02:22:00 03:58:00	
13	CHP	CC-51	TRIPPED ON OLR	RESET DONE	02:45:00 05:15:00	02:50:00 05:20:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/10/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-54	OLR ACTED	RESET DONE	03:00:00 03:10:00	03:05:00 03:15:00	
15	WT	CC-3	TRIPPED ON OLR (2 TIMES)	RESET DONE	23:45:00	00:10:00	