



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 17/08/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR acted	reset done	00:45:00	00:55:00	
2	OHP	BRC on CO 28	LT not taking place due to mpcb tripped	made on	23:20:00	23:40:00	
3	OHP	WOBR on CO 29	ZSS probe problem	changed new probe	01:50:00	02:10:00	
4	OHP	BRC on CO 28	LT not taking place due to mpcb tripped , material on track	made on	01:00:00	01:20:00	
5	OHP	CO 64	MPCB tripped	made on	02:10:00	02:25:00	
6	OHP	BRC on CO 30	CT , LT control cables burn	smps replaced , plc problem	02:10:00	06:00:00	work going on
7	OHP	CO 15	OLR acted	reset done	05:45:00	05:50:00	
8	OHP	CO 30	OLR acted	reset done	02:45:00	02:50:00	
9	OHP	BRC on CO 31	M6 tripped due to track jamming	reset done	05:40:00	05:55:00	
10	CHP	CC 14	Belt drive tripped due to unbalance fault	reset done	23:25:00	23:35:00	
11	CHP	CC 27A	Tripped due to overload	reset done	22:25:00	22:35:00	
12	CHP	RG 2	Stopped on under speed	checked, no electrical problem found	01:20:00	01:40:00	
13	CHP	CC 54	Tripped on overload (4 times)	reset done	01:05:00	05:00:00	
14	CHP	CC 113	Stopped on zero speed	checked, pully jamming , informed to operation	05:25:00	05:35:00	
15	CHP	CC 112 , S 3	PCRD cable old joint problem from B shift	Joint done by DNW , then machine charged and clearance given	22:00:00	01:45:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/08/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 39 , S -1	LT reverse not working due to end limit acting	end limit bypassed , all checked and again limit kept in circuit	23:20:00	23:40:00	
17	CHP	CC 34 , SCR 2	BC frequently stopping due to ZSS cage stuck	ZSS bypassed	23:50:00	00:00:00	cage to be changed, refer to A shift
18	CHP	CC 31 , R 1	Luff not working due to air lock problem	air lock release , luffing done	02:50:00	03:00:00	
19	WT	OT 5	D1 and D2 tripped	made on	00:00:00	00:05:00	
20	WT	OT 3	D 1 tripped	made on	01:50:00	01:55:00	