



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/06/2025

Shift: C

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR ACTED (2TIMES)	RESET	00:00:00	00:10:00	
2	OHP	BRC ON CO 31	B/C OLR ACTED	RESET	00:15:00	00:30:00	
3	OHP	TBS ON CO20	LT NOT TAKING PLACE O/T ACTED	RELEASED	00:15:00	00:30:00	
4	OHP	BRC ON CO28	B/C OLR ACTED(2TIMES)	RESET	02:40:00	02:50:00	
5	OHP	WOBR 6A	SLEW NOT WORKING	SPEED ADJUSTED	02:00:00	02:30:00	
6	OHP	BF 9A	STOPPING ON ZS	PROBE GAP ADJUSTED	02:00:00	02:40:00	
7	CHP	CC117	OLR ACTED	RESET	22:30:00	22:40:00	
8	CHP	CC131	OLR ACTED(2TIMES)	RESET	04:00:00	05:10:00	
9	CHP	CC40 SCR 6	C/S ACTED DUE TO JAMMING	INFORMED TO OPERATION	23:10:00	23:20:00	
10	CHP	CC 40 SCR 6	LT NOT TAKING PLACE	WRONG COMPLAINT	23:20:00	23:30:00	
11	CHP	CC39 SCR 7	B/C NOT RUNNING GVM SIDE SIGNAL MISSING IN CCR	BY PASSED	03:10:00	03:20:00	
12	CHP	CC48	BRS NOT REST	SENSOR CLEANING THAN OK	01:30:00	01:50:00	
13	CHP	CC111 S 3	SIGNAL PROBLEM	PLC AND ANTENNA BOTH SIDE ETHERNET CABLE CLEANING AND RE CONNECTED	04:15:00	05:00:00	
14	CHP	CC111 S3	B/C OLR ACTED	RESET	04:50:00	05:00:00	
15	CHP	CC 28	OLR ACTED	RESET	22:40:00	22:45:00	