



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 29/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 6A	luffing not working,electrical side checked all ok luffing pipe damaged	informed mechanical and operation	12:45:00	13:10:00	
2	OHP	TBS on co 20	LT not working,drive tripped	reset done	06:20:00	06:35:00	
3	OHP	TBS on co 22	left b/c not running, olr acted	reset	11:00:00	11:15:00	
4	OHP	BRC on Co 32	bc not running,PB operated@cabin	released	11:10:00	11:25:00	
5	OHP	TBS on CO 19	L/BC not running due to mpcb tripped	reset	11:20:00	11:35:00	
6	OHP	WOBR on Co 26	slew not working,drive tripped	reset	11:25:00 13:15:00	11:45:00 13:30:00	
7	OHP	wobr on co 29	luff not working,control mcb is in off	made it on	12:20:00	12:36:00	
8	OHP	RSCO 6A	olr acted	reset	12:30:00	12:40:00	
9	OHP	bRC on co 34	yard conveyor running signal not coming,zss yard interlock checked found ok,BW2 MCCB flash observed	pending	12:29:00	14:30:00	
10	CHP	CC 38 scr 6	LT not working,drive tripped	reset	10:05:00	10:15:00	
11	CHP	cc 44	olr acted	reset	12:35:00	12:40:00	
12	CHP	CC 33 SCR 5	LT not working,OT acted	OT released	13:25:00	13:35:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	C 32 R1	b/c not running,zss interlock cage stucked with stone	cage made free	13:25:00	13:35:00	
14	CHP	C 114	olr tripped	reset	08:10:00	08:15:00	
15	CHP	CC 117	OLR acted	reset	08:30:00	08:45:00	
16	CHP	CC 56	olr acted	RESET	09:40:00	09:45:00	