



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/12/2025

Area: CHP

Equipment	Job
CC 116,RG 3	5nos 50W LED and one 250W SV fixture provided
CC 14,18,23	PPM was done
IC -2 to IC 6	Lamp fixtures provided with switch control
CC 222/223 Belt scale	Maintenance was done
CC 38,SCR 6	Running inspection was done
CC 46,47,50	PPM was done