



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/11/2025

Area: WT

Equipment	Job
CP 3	Trolley line inspection done ,track sink points noted and informed Traffic/Railways
LC 1 and 9	All panel doors inspected and closed
OP 9	Panel and Motor side ppm done
OP 3 and 1	After rake maintenance done, OP 1 found bottom C clamp bent ,replaced it
MIS	coal tippler walk way Bridge area lighting contactor and one MCB 10A replaced