



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/06/2025

Area: CHP

Equipment	Job
CC-25	Control cable checked and found cable burnt at slope area.10mtrs cable joint done,terminated and field devices checked and tested okay.ZSS module shifted at site.