



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 08/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-5A	REPORTED R/LUFF OLR ACTED	RESET DONE	06:55:00	07:10:00	
2	OHP	BRC ON CO-32	REPORTED B/W-1,2 NOT RUNNING FOUND XMD PANEL GLASS FUSE BLOWN	FUSE REPLACED THAN OK	09:55:00	10:10:00	
3	OHP	TBS ON CO-5A	LT NOT TAKING PLACE M-2 OLR ACTED	RESET DONE	09:40:00	09:50:00	
4	CHP	CC-54	TRIPPED ON OLR (5TIMES)	RESET DONE	07:40:00	13:20:00	
5	CHP	CC-51	FEEDING CONVEYOR MPD TRIP	RESET DONE	11:10:00	11:20:00	
6	CHP	CC-32 R-1	REPORTED B/C NOT RUNNING FOUND INTERLOCK ZSS CAGE STUCK UP WITH COAL PICK	REMOVED THAN OK	07:50:00	08:05:00	
7	CHP	CC-38 SCR-6	REPORTED LT NOT TAKING PLACE FOUND O/T ACTED	RELEASED THAN OK	12:40:00	12:50:00	
8	WT	CO-3 BELT DRIVE	TRIPPED ON OLR (10TIMES) DUE TO JAMMING AND BELT PROBLEM	RESET DONE	09:00:00	13:20:00	
9	IOSA	OC-27A	REPORTED STOPPING ON ZSS CHECKED AND FOND MATERIAL JAMMING	INFORMED TO OPERATION	09:05:00	09:30:00	
10	IOSA	OC -27A	TRIPPED ON OLR DUE TO JAMMING	RESET DONE	12:20:00	12:35:00	