



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 01/11/2025

Area: WT

Equipment	Job
OP 10	C type isolator boxes @ col no 56 and 57 inspection done, found OK
OP 10	D5 motor TB removed, winding lugs replaced and direct termination done, kept in circuit
OP 2 ,8 and CP 3	After rake maintenance done