



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 14/02/2026

Area: WT

Equipment	Job
OP 10	Antenna pipe and Antenna fixed ,Ethernet cable checked and connected
OP 10	All drives checked and moved in LOCAL
OP 10	Trolley line inspection done
OP 10	After col no78 Mast is touching to Trolley line,brought to maintenance zone
OP 3	D3 Motor removed for gear box repair job
OP 3	After rake maintenance done