



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 22/12/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-11(C/D)	Reported not moving	MPCB tripped.Made on	00:30:00	00:00:00	
2	OHP	Co-26	Reported tripped	OLR acted.Reset done	01:10:00	01:20:00	
3	OHP	VS-1A	Reported tripped	OLR acted.Reset done	01:45:00	01:55:00	
4	OHP	Stacker on Co-19	LBC not running	ZSS cage stuck with stone.Removed and tested okay	05:00:00	05:20:00	
5	OHP	CO-65	Reported ZSS acting	ZSS cage damaged.Replaced	02:05:00	02:35:00	
6	CHP	CC 117	Reported tripped	OLR acted.Reset done	05:10:00	05:20:00	
7	CHP	CC-51A	Reported tripped	OLR acted.Reset done	04:40:00	04:45:00	
8	CHP	CC 131	Reported tripped	OLR acted.Reset done	04:00:00 05:30:00	04:05:00 05:35:00	
9	CHP	CC 54	Reported tripped	OLR acted.Reset done	05:20:00	05:25:00	
10	CHP	CC 33 R1	B/C not running	ZSS cage stuck.Made free	22:40:00	23:00:00	
11	CHP	CC 34 SCR-1	Luff not working	Up limit acted.Released and tested okay	05:00:00	05:20:00	
12	WT	Ot-4	Reported tripped	D2 tripped on PGEF-4 fault.Reset done	05:30:00	05:36:00	