



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/12/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 111(b)	olr acted	reset	15:30:00	15:35:00	
2	OHP	co 46	pc acted	reset	14:50:00	14:55:00	
3	OHP	TBS on CO 20	Left B/C olr acted	reset	18:30:00	18:45:00	
4	OHP	VS 2A	OLR acted	reset	20:32:00	20:40:00	
5	OHP	CO 25	OLR acted	reset	20:40:00	20:50:00	
6	CHP	CC 25 TT	position indication missing,loosed connection in i/o rack	tightened	16:20:00	16:30:00	
7	CHP	cc 45	olr acted	reset	16:30:00	16:40:00	2 times
8	CHP	CC 51	mpd tripped	reset	17:54:00	18:00:00	
9	CHP	CC 54	OLR acted	reset	20:10:00	20:15:00	
10	CHP	cc 58	OLR acted	reset	18:42:00	18:51:00	2 times
11	WT	OT 4	D1 tripped in pgf1 fault	reset	16:00:00	16:10:00	