



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/07/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	22:20:00	22:25:00	
2	OHP	WOBR ON CO 25	SLEW NOT WORKING M1 OLR ACTED	RESET	23:30:00	23:40:00	
3	OHP	TBS ON CO21	L/LUFF MPCB TRIP	RESET	00:00:00	00:15:00	
4	OHP	BRC ON CO 34	B/W 1 AND B/W 2 NOT RUNNING GUIDE ROLLER FELLDOWN	IN FORMED TO MECH	00:00:00	00:20:00	
5	OHP	CO 17	OLR ACTED	RESET	01:00:00	01:05:00	
6	OHP	CO 29	OLR ACTED(3TIMES)	RESET	01:10:00	01:20:00	
7	OHP	CO 32	OLR ACTED	RESET	01:30:00	01:35:00	
8	OHP	CO 15	ZS PROBE WIRE GOT CUT	JOINT DONE THAN OK	02:20:00	02:40:00	
9	OHP	TT 4	LT NOT TAKING PLACE POWER MCB TRIP	MADE ON	02:40:00	02:45:00	
10	OHP	CO 24	OLR ACTED	RESET	03:30:00	03:45:00	
11	OHP	BRC ON CO 34	YARD CONVEYOR INTER LOCK ZS CABLE GOT CUT	RE JOINT DONE	05:00:00	05:15:00	
12	OHP	CO 50	C/S PROB CONNECTIONS REMOVED CONDITION	RE CONNECTED THAN OK	22:30:00	22:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/07/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 33 SCR 4	no power, heavy flash sound came from T/F, 2 no of HT fuse (side) blown	megger done for coupler to slip ring and isolator to slip ring found OK, T/F Ph TO E IR value zero	22:30:00	02:00:00	full transformer drenched by CISF fire wing water spray, to be checked in G shift
14	CHP	CC 27	stop in ZSS fault, mech gear box problem oil leakage	informed mechanical	23:00:00	23:10:00	
15	WT	op3	Pusher moved to no power zone after last wagon	pusher moved back to power zone	23:00:00	23:20:00	no delay