



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 12/12/2025

Area: IOSA

Equipment	Job
OC-23A	MAINTENANCE DONE ON HT BREAKER.
OC-27A	PROVIDED POWER TO HOT JOINTING KIT. LIGHTING AND EXTENSION BOX POWER PROVIDED.
OC-29A	LIGHTING DEFECTS RECTIFIED AND PROVIDED LIGHT FITTING.
OC-23A	LIGHTING CIRCUIT RECTIFIED AND PROVIDED LIGHT FITTINGS.
BLENDER RECLAIMER	BLENDER BROUGHT BACK TOWARDS H/E . OBSERVED SOUND COMING FROM LT MOTOR-4 AND GEARBOX. PCRD CABLE IS GETTING UN-WINDING DURING THE OPERATION. PCRD PROBLEM RECTIFICATION IN PROGRESS.
MISC	SPARE MOTOR AT OC-29A H/E MEGGERING DONE. IR VALUES RECORDED.
OC-29A	PPM DONE ON MOTOR AND FIELD DEVICES