



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/07/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RBF 2A	not healthy ,control mcb trips due to e/f in PC	cable problem spare core used for pull chord,all interlock in ckt	07:45:00	08:20:00	
2	CHP	SCR 9 on cc 104	LT not taking place,OT acted	OT released	07:55:00	08:05:00	
3	CHP	CC 35 SCR1	PCRD fallen on ground	pcrd winding done than all ok	07:30:00	08:05:00	
4	CHP	CC 125	trips in overload	reset	12:10:00	12:20:00	
5	CHP	Cc 105 scr 7	b/w cooler fan cable joint opened	cable jointed ,dressing done checked found ok	10:30:00	11:00:00	
6	CHP	CC 54	OLR acted	reset	07:20:00	07:30:00	
7	WT	OT 1	initial problem	initial adjusted ,fwd limit and rev limit	06:15:00	06:50:00	
8	WT	SCO 1A(B)	olr acted	reset	13:00:00	13:05:00	