



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/12/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 58	control tripped due to earth fault in PC	PC isolated and bypassed	18:30:00	18:45:00	PC to be checked
2	OHP	CO 26	OLR acted	reset	14:20:00	14:30:00	3 times
3	OHP	CO 85	olr acted	reset	17:20:00	17:30:00	
4	OHP	CO 25	olr acted	reset	18:30:00	18:40:00	
5	CHP	cc 26	zss module problem	probe replaced, zss bypassed,module changed	17:00:00	17:12:00	
6	CHP	CC 37 scr 7	b/c not running,mpd tripped	reset	18:30:00	18:40:00	
7	CHP	CC 33 R1	luffing not working,olr acted	reset	20:30:00	20:45:00	
8	WT	OP 10	no movement,D3,b phase got melt	d3 power made off and bypass in SCADA system	16:40:00	17:10:00	
9	WT	OP 10	no movement,D1,D4,D5 healthy not coming,after some time all drive healthy not coming,PLC problem	communication checked,control checked found all drive OK not coming,made high in logic and LCS rev continuous made force low,checked and found lcs REV contact problem	19:10:00	19:55:00	