



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/12/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	tripped on olr.	reset done	11:40:00	11:50:00	
2	OHP	jh -2	hoist not working./no power /tripped at LC -3	MPCB made on.then ok	11:30:00	11:40:00	
3	OHP	co 25	tripped on olr	reset done	08:50:00	09:00:00	
4	OHP	co 29	tripped on olr	reset done.	12:30:00	12:40:00	
5	CHP	cc 26	brs acted due belt peices	reset done.	07:30:00	07:40:00	
6	CHP	scr 2 on cc40	b w not working/bw stuckup with iron sheet.	informed to mech. and ope.,	11:00:00	11:10:00	
7	CHP	scr 9 on cc104	slew not working/pb loose	pb tighten .then ok	11:00:00	11:10:00	
8	CHP	cc 40	tripped on olr	reset done.	11:22:00	11:27:00	
9	CHP	cc 51	md tripped on olr 2 times	reset done.	09:10:00	09:15:00	
10	CHP	cc 54	tripped on olr	reset done	08:10:00 13:02:00	08:15:00 13:07:00	