



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 05/08/2025

Shift: B

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

| Sl No | Area | Equipment       | Problem  | Action  | From     | To       | Remarks                                   |
|-------|------|-----------------|--|---|----------|----------|---|
| 1     | OHP  | CO33M           | Hydraulic pump not working found oil level low showing in operator cabin | Informed to mechanical and operation after filling oil ok | 15:30:00 | 16:00:00 | Not an electrical complaint               |
| 2     | OHP  | CO26            | olr acted 2 times  | Reset done  | 16:30:00 | 16:40:00 | 07.15pm to 07.25pm                        |
| 3     | OHP  | VS4a            | olr acted  | reset done  | 18:20:00 | 18:30:00 |   |
| 4     | OHP  | CO33m           | olr acted  | Reset done  | 19:00:00 | 19:05:00 |   |
| 5     | OHP  | Co11 (carriage) | olr acted  | Reset done  | 20:30:00 | 20:33:00 |   |
| 6     | OHP  | WOBR on CO6a    | BW not rotating charge pressure acted                                    | Informed to mechanical                                    | 19:20:00 | 19:30:00 |   |
| 7     | OHP  | CO33a           | BRS bypassed as per operation request                                    | Again placed in ckt as per operational request            | 18:00:00 | 22:05:00 |   |
| 8     | CHP  | CC19            | Over load acted 2 times  | Reset done  | 14:40:00 | 14:45:00 | 03.30 pm to 03.35pm                       |
| 9     | CHP  | CC114           | olr acted  | Reset done  | 19:10:00 | 19:15:00 | 08.30pm to 08.35pm and 09.50pm to 09.55pm |
| 10    | CHP  | CC54            | over load acted 4 times  | Reset done  | 18:05:00 | 18:30:00 |   |
| 11    | CHP  | CC52            | Changed from DOL to VFD  | trail run taken   | 14:30:00 | 16:30:00 |   |