



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment     | Problem  | Action  | From     | To       | Remarks  |
|-------|------|---------------|--|---|----------|----------|----------|
| 1     | OHP  | co 67         | olr acted  | reset   | 08:25:00 | 08:30:00 |          |
| 2     | OHP  | co 26         | olr acted  | reset   | 09:15:00 | 09:25:00 |          |
| 3     | OHP  | TIS 2         | failed to start,push button problem  | push button replaced  | 08:30:00 | 08:50:00 | no delay |
| 4     | CHP  | CC 39<br>SCR6 | all drive not working,main contactor not pickup,ePB @operator cabin NO contact problem | bypassed contact and informed G shift   | 08:30:00 | 08:40:00 |          |
| 5     | CHP  | CC 201        | olr acted  | reset   | 08:55:00 | 09:00:00 |          |
| 6     | CHP  | CC35 scr3     | b/c not running,olr acted  | reset   | 09:25:00 | 09:35:00 |          |
| 7     | CHP  | CC 32         | yard conveyor not working,mpd tripped  | reset   | 08:10:00 | 08:15:00 |          |
| 8     | CHP  | CC 51         | MPD acted 3 times  | reset   | 07:20:00 | 07:25:00 |          |
| 9     | CHP  | CC 131        | olr acted  | reset   | 13:45:00 | 13:50:00 |          |
| 10    | WT   | CT            | communication problem  | modem replaced,and configuration done in modem                                      | 06:00:00 | 06:45:00 |          |
| 11    | WT   | OP4           | no movement,communication problem  | LC1 and LC2A side modem power recycle done and ethernet cable plugged and unplugged | 13:30:00 | 14:00:00 |          |