



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/01/2026

Area: WT

Equipment	Job
OP 6	Section isolators maintenance done,2 nos (col no:84 and 91)
OP 5	Section Isolators maintenance done ,5nos (col no:67,72,79,87,93)
OP 2 and 5	After rake maintenance done
MIS	Bed drain pumps inspection done both Tipplers and status informed to WMD
MIS	75W sample LEDs installed one @ OAF level and one @ LC 10B entrance area