



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/11/2025

Shift: A

Incharge(s): Lal Singh,Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-32	BW-1 NOT RUNNING	STUCK ... RUN IN REV THEN OK	12:30:00	12:40:00	
2	CHP	CC-51	MPD TRIPPED	RESET DONE	08:11:00	09:15:00	
3	CHP	CC-38SCR-6	LT DRIVE PROBLEM FROM C SHIFT	DRIVE PARAMETERS CHANGED WITH ETL .. STILL NOT WORKING DOL WIRING DONE FOR LOCAL OPERATION AND GIVEN CLEARNESS FOR RECLAIMING	06:00:00	10:00:00	DRIVE CHANGING GOING ON
4	CHP	CC-27A TO CC-39	TT POSITION SLECTION NOT COMING	SLECTION NOT DONE IN CCR ... NO ELECTRICAL PROBLEM	10:30:00	11:00:00	
5	CHP	CC-112 S-3	BC NOT RUNNING	ZSS CAGE STUCK ... MADE FREE	06:30:00	06:40:00	
6	CHP	CC-34 SCR-1	LT DRIVE TRIPPED	RESET DONE	06:30:00 12:40:00	06:40:00 12:45:00	
7	CHP	CC-32 R-1	LUFF NOT WORKING	MPCB TRIPPED ... RESET DONE	06:35:00	06:45:00	
8	CHP	CC-125	TRIPPED ON OLR	RESET DONE	08:30:00	08:35:00	
9	CHP	CC-105 SCR-10	LT NOT WORKING	TRACK JAMMING INFORMED OPERATION	08:40:00 10:30:00	08:55:00 11:00:00	
10	CHP	CC-32 R-1	BW NOT WORKING	MECH PROBLEM	09:30:00	09:50:00	
11	WT	OP-1	D-4 SLIP RING PROBLEM	COIL CONNECTION REMOVED AND DCLUCHED	09:00:00	09:20:00	