



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/06/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS 1A	chute sensor acted, stone stucked	operation cleaned	00:55:00	01:05:00	
2	OHP	Co 26	olr acted	reset	02:10:00	02:20:00	
3	OHP	CO 24 TBS	no power, y phase missing	checking going on	22:00:00	06:30:00	
4	CHP	CC 36 scr1	slew not working, mpcb trip	made it on	02:35:00	02:44:00	
5	CHP	CC 48	motor healthy stop, BSS acted	BSS released than ok	02:55:00	03:10:00	
6	CHP	CC 201 and 203	not healthy, MPD trips in Over load	over load reset	03:35:00	03:50:00	
7	CHP	CC 202	local selection show in CCR, PC and emergency acted	PC and emergency released	03:40:00	04:10:00	
8	CHP	CC 40 SCr 6	slew not LT not working	wrong complaint by operator	04:40:00	04:50:00	
9	CHP	CC 33 SCR4	LT not working, drive trips in overload	reset	05:10:00	05:20:00	