



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/05/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	cc 131	tripped on olr	reset done	17:05:00	17:10:00	
2	CHP	cc 108	brs kept in ckt	operation request	16:00:00	16:10:00	
3	CHP	cc 107	brs bypass request from ope.	bypassed	16:00:00	16:10:00	
4	CHP	scr 5 on cc32	bc c/s acted and probe damaged and fuse bloen	probe and fuse replaced .then ok	16:40:00	17:00:00	