



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/08/2025

Area: OHP

| Equipment | Job |
|------------------------|--|
| CR1A | CANOPY PROVIDED FOR ZSS PROBE |
| CC 109 | 2 NOs 120 LEDS FIXED AT TAIL END |
| CC-8 | FINGER CONTACTOR BUSBAR NUT BOLT REPLACED (3NOs) |
| TT2 | OLD JOINT CABLE INSULATION DONE PROPERLY |
| 18.5 KW MOTOR | SHIFTED FROM 1-28HVMCC1 TO JH-3 |
| 37.5 KW MOTOR | SHIFTED FROM 1-14LC7 TO JH3 |
| TBS 4 ON CO 5A | AFTER MECH GUIDE ROLLERS PROBLEM CLEARANCE WINDING DONE PROPERLY |
| TBS ON CO 21 | B/C MOTOR COVERED WITH BELT PIECE |
| TBS ON CO 21 RIGHT B/C | ZSS CAGE BOLT FIXED |
| CO16, TT3 | PPM DONE |
| co-68 | schneider mpr is installed and ctmf relay is removed. |