



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/05/2025

Incharge(s): K SANKARA RAO

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--------------------------------------|---------------------------|----------|----------|---------------|
| 1 | OHP | WOBR ON CO 26 | LT NOT TAKING PLACE PCRD O/T ACTED | RELESED | 03:15:00 | 03:30:00 | |
| 2 | OHP | TBS ON CO 19 | LEFT LUFF NOT TAKING PLACE OLR ACTED | RESET | 03:45:00 | 04:00:00 | |
| 3 | OHP | CO 27A | MAIN CONTACTOR CHATTRING | ALL CONTROL WIRES TIGHTED | 03:15:00 | 04:00:00 | |
| 4 | CHP | CC 35 S1 | LT NOT TAKING PLACE O/T ACTED | RELEASED | 02:40:00 | 02:50:00 | |
| 5 | CHP | CC 105 SCR 10 | B/C NOT RUNNING C/S ACTED | PROBE CLEANING DONE | 05:25:00 | 05:35:00 | |
| 6 | WT | PO 5 | F/W NOT MOVING D2 TRIPPED | RESET | 23:40:00 | 23:50:00 | COUPLING TIME |