



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 11/12/2025

Area: IOSA

Equipment	Job
OC-7A	Head end hoist motor fixing work is in progress.
BLENDER RECLAIMER	Brought blender 200 mtrs back towards transfer car.
OC-37A	PPM done on motor and field devices.
OC-27A	Lighting arranged and switch board connection given. Head end and tail end electrical hoist checked.
OC-27A	Cable shifted from OC-7B conveyor gallery to OC-27A head end for belt joint purpose.