



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/02/2026

Area: WT

| Equipment | Job |
|----------------|---|
| OP 10 jobs | Mast placed and alignment done (welding work is going on) |
| OP 10 jobs | Old panel stools removed and made new stool and placed D B Rs |
| OP 10 jobs | D1 Motor cable jointing done and 1 no D B R shifted from new building |
| EOT Crane(O) | Main Hoist ,brake rectifier replaced |
| OP 2 , 3 and 6 | After rake maintenance done |